



CERTIFICATE

This is to certify that :

2 Aircooler(s) Cu/Al Goldlack

has (have) been tested for tightness and strength .	Project no.	Kelvion	: 200552147 / 40
Strength test on tube side:	Order no. customer		: PO20111357-1/241210470
PT = 115 bar	Drawing no.		: 200552147-040.000-1
Test(s) with air pressure whilst submerged in water.	Type		: Kelvion CSF-451-4BE
Leakages and unacceptable distortions were not observed.	Capacity [W]		: 7260
	Medium		: R744 (CO2) DE
	PS [bar]		: 80
	TS [°C]		: -40/100°C
	Tube volume [dm ³]		: ±4
	Test date		: 05-04-2023

Signed for Kelvion Refrigeration B.V. (manufacturer) by:



Mr. A.A. Heijboer
Product Expert

Kelvion Refrigeration B.V.

Nijverheidsweg 6, 4695 RC Sint Maartensdijk,
The Netherlands
Phone: +31 (0)166 665 665
E-mail: sint-maartensdijk@kelvion.com

www.kelvion.com



Management
System
ISO 9001:2015
ISO 14001:2015
ISO 45001:2018
www.tuv.com
ID 9000002236

