



CERTIFICATE

This is to certify that :

4 Aircooler(s) Cu/Al Goldlack

has (have) been tested for tightness and strength .	Project no. Kelvion	: 200552783 / 10
Strength test on tube side:	Order no. customer	: Po20111357-2/241210407
PT = 115 bar	Drawing no.	: 200552783-010.000-1-C
Test(s) with air pressure whilst submerged in water.	Type	: Kelvion CSF-451-6BE
	Capacity [W]	: 243000
	Medium	: R744 (CO2) DE
Leakages and unacceptable distortions were not observed.	PS [bar]	: 80
	TS [°C]	: -50/100°C
	Tube volume [dm ³]	: ±7
	Test date	: 07-04-2023

Signed for Kelvion Refrigeration B.V. (manufacturer) by:



Mr. A.A. Heijboer
Product Expert

Kelvion Refrigeration B.V.

Nijverheidsweg 6, 4695 RC Sint Maartensdijk,
The Netherlands
Phone: +31 (0)166 665 665
E-mail: sint-maartensdijk@kelvion.com

www.kelvion.com



Management
System
ISO 9001:2015
ISO 14001:2015
ISO 45001:2018
www.tuv.com
ID 9000002236

